



Kotville
J Wautersstraat 61
8200 Sint-Michiels

Datum meting: 21 april 2016
Technieker: Kris Pawelec
Dossiernummer: 31005-G-20133022
Meesstoel: Testo 417 SNO1800788

Lieven Decat

Ventilator 2L			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
224	50	53	52
225	50	51	51
226	50	55	53
227	50	50	53
228	55	55	54
229	50	52	50
230	50	52	51
231	50	53	52
232	50	50	51
233	65	66	65
235	75	78	79
Gem. ruimte 0K01	125	130	129
Totaal	770	796	791

Ventilator 1L			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
124	50	50	52
125	50	55	54
126	50	53	55
127	50	53	51
128	55	56	58
129	50	51	53
130	50	52	52
131	50	55	54
132	50	50	53
133	50	52	51
134	65	65	65
135	75	78	76
Gem. ruimte 0K01	125	129	127
Totaal	770	799	801

Ventilator 0L			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
024	50	55	53
025	50	52	51
026	50	53	52
027	50	51	50
028	55	56	55
029	50	50	52
030	50	52	51
031	50	54	53
032	50	52	52
033	50	50	53
034	55	55	57
035	75	76	75
Gem. ruimte 0K01	125	127	125
Totaal	760	783	779

Ventilator 2M			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
201	60	62	62
202	65	66	67
203	65	68	67
215	50	51	50
216	50	54	52
217	50	52	51
218	125	127	126
219	70	72	71
220	125	126	126
221	50	53	52
222	50	50	51
223	50	51	52
236	50	53	53
237	50	53	51
238	50	50	52
239	125	127	125
240	50	50	54
241	60	64	62
Gem. ruimte 2K02	125	126	127
Totaal	1320	1355	1352

Ventilator 1M			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
101	60	61	60
102	65	67	65
103	65	68	67
115	50	51	50
116	50	51	53
117	50	50	51
118	125	128	126
119	70	73	72
120	125	128	127
121	50	51	50
122	50	50	54
123	50	52	51
136	50	54	51
137	50	53	51
138	50	54	53
139	125	128	127
140	50	50	51
141	60	61	60
Gem. ruimte 1K02	125	126	129
Totaal	1320	1356	1348

Ventilator 0M			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
001	60	62	62
002	65	68	67
003	65	67	69
015	50	55	55
016	50	53	52
017	50	52	51
018	125	129	129
019	125	126	125
020	125	128	127
021	50	53	53
022	50	52	51
023	50	55	54
036	50	54	53
037	50	51	51
038	50	52	51
conclérgewoning	165	170	166
Gem. ruimte 0K02	125	127	125
Totaal	1305	1352	1341

Ventilator 2R			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
204	50	52	50
205	60	63	61
206	60	64	61
207	60	61	61
208	60	63	62
209	75	76	77
210	70	72	71
211	50	52	50
212	55	58	57
213	65	66	67
214	70	71	70
Gem. ruimte 2K03	125	127	125
Totaal	800	825	812

Ventilator 1R			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
104	50	52	50
105	60	65	65
106	60	62	62
107	55	60	58
108	55	56	55
109	70	72	71
110	70	71	70
111	50	52	50
112	55	56	59
113	65	67	68
114	70	71	70
Gem. ruimte 1K03	125	128	127
Totaal	785	810	805

Ventilator 0R			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
004	50	51	50
005	60	65	64
006	60	62	61
007	55	58	56
008	55	55	58
009	70	72	71
010	70	71	71
011	50	52	53
012	55	55	55
013	65	69	70
014	70	71	70
Gem. ruimte 0K03	125	126	127
Totaal	785	807	806

Ventilator 3M			
Kamer	Vereist m³/h	gemeten Pulsie m³/h	Gemeten Extractie m³/h
301	75	78	77
302	125	129	128
303	75	77	76
304	75	75	77
305	75	76	76
Gem. ruimte 3K02	75	76	78
Totaal	500	511	512

ing: **Brecht Venninckx**